

DECLARATION OF PERFORMANCE

DoP n° : **Sitek_DoP_33_Batiboard 550+**

1. Unique identification code of the product-type:

Batiboard 550+

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

Batiboard 550+ (see product label)

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

As given in ETA 22/0442

3.1 Use category Type 4 as defined in EAD 350142-00-1106 (Fire protective products to protect load-bearing steel elements).

3.2 For use in internal conditions, type Z2 as defined in EAD 3501-00-1106.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

**Sitek Insulation S.A.S.U
Route de Lauterbourg
CS 90148
67163 Wissembourg Cedex
France**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

See Section 9 below.

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

This construction kit is not covered by a Harmonised Standard (hEN)

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

The Declaration of Performance concerns a construction kit for which a European Technical Agreement has been issued

By UL International Netherlands

Issued as ETA 22/0442 in accordance with Article 29 of the Regulation (EU) No 305/2011

On the basis of EAD 350142-00-1106 for Fire protective board, slab and mat products and kits, September 2017

Performed under system AVCP 1

And issued certificate of consistency of performance number 2821 -CPR-0244 by UL International (Notified Body 2821)

9. Declared performance

Product: Fire Protective Material		Intended use: Fire Protection of Structural Steel Elements
Basic requirement for construction work	Basic Requirement	Performance
BWR 1 Mechanical resistance and stability		
-	None	No performance declared
BWR 2 Safety in case of fire		
EN 13501-1	Reaction to fire	Board: Class A1 Fastener: Class A1
EN 13501-2	Resistance to fire	Annex A R360
EN 12467:2012	Durability	Type Z2
BWR 3 Hygiene, health and environment		
-	None	No performance declared
BWR 4 Safety in use		
-	None	No performance declared
BWR 5 Protection against noise		
-	None	No performance declared
BWR 6 Energy economy and heat retention		
EN 12667	Thermal resistance	No performance declared

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Benoit Morizot, Plant Manager

Wissembourg, May 10th, 2023

n° DoP : Sitek_DoP_33_Batiboard 550+ – English – Validity started from : 10/05/2023